



Office of the District Fire Officer
Karnataka Fire & Emergency Services Department
Mahadevapura Fire Station
Garudachar Palya, Bengaluru-560 048.



No. 35/DFO/MFS/FSCR/2022

Dated: 24-08-2022.

"Annexure-2"

To,
The Authorized Signatory
M/s. Rainbow Innovative Academy,
No.24/4, Konadasapura, Virgonagar Post,
Bidarahalli Hobli, Bangalore-560 049.

Sir,

Sub : Issue of "Fire Safety Compliance Report" with respect to fire prevention, fire fighting and evacuation measures maintained at "M/s. Rainbow Innovative Academy, No.24/4, Konadasapura, Virgonagar Post, Bidarahalli Hobli, Bangalore-560 049" - reg.

Ref : 1) FSR No.35/DFO/MFS/FSR/2022, Date: 24-08-2022.
2) Your request letter dated: 09-08-2022.

<<<>>>

With reference to the above cited subject, as per ref(1), a conditional Fire Safety Recommendation was issued to the premises of "M/s. Rainbow Innovative Academy, No.24/4, Konadasapura, Virgonagar Post, Bidarahalli Hobli, Bangalore-560 049" with a condition to fulfill the recommendations and compliance the same within 3 months.

With reference cited (2) above, the management of "M/s. Rainbow Innovative Academy" had requested for the fire safety compliance report from our department. In this regard the above addressed educational building was inspected by me on 10-08-2022 for issue of fire safety compliance report.

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing the "Fire Safety Compliance Report" to "M/s. Rainbow Innovative Academy, No.24/4, Konadasapura, Virgonagar Post, Bidarahalli Hobli, Bangalore-560 049" subject to proper maintenance of fire fighting installations in the good working conditions and arrange for 40% of staffs/ employees training within 03 months from the date of issue of this report. "This Fire Safety Compliance Report is valid for Only One Year from the date of issue and it is renewable"



Yours faithfully


DISTRICT FIRE OFFICER
MAHADEVAPURA FIRE STATION
BANGALORE



**Office of the District Fire Officer,
Karnataka Fire & Emergency Services,
Mahadevapura Fire Station
Garudachara Palya, Bengaluru-560 048.**



No. 35/DFO/MFS/FSR/2022

Dated: 24-08-2022.

ANNEXURE – 1

Group - B Educational Building

NBC-2016, Part-4, Table 7(11) 3.1.3 Group B Educational Buildings Sub Division B1 & B2.

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC-2016 are mandatory).

To,
The Authorized Signatory
M/s. Rainbow Innovative Academy,
No.24/4, Konadasapura, Virgonagar Post,
Bidarahalli Hobli, Bangalore-560 049.

Sir,

Sub : Issue of “**Fire safety recommendation**” with respect of fire prevention, fire fighting and evacuation measures required at “M/s. Rainbow Innovative Academy, No.24/4, Konadasapura, Virgonagar Post, Bidarahalli Hobli, Bangalore-560 049”- reg.

Ref : Your request letter dated: 09-08-2022.

<<<>>

With reference to the subject cited above, the premises of “M/s. Rainbow Innovative Academy, No.24/4, Konadasapura, Virgonagar Post, Bidarahalli Hobli, Bangalore-560 049” was inspected by me on 10-08-2022 with respect to Fire prevention, Fire fighting and Evacuation measures to be complied in the above premises and has submitted the details as under.

A. Details of the building / premises :-

01	Name and Address of the Applicant.	:	The Authorized Signatory M/s. Rainbow Innovative Academy, No.24/4, Konadasapura, Virgonagar Post, Bidarahalli Hobli, Bangalore-560 049.
02	Name and Address of the premises.	:	M/s. Rainbow Innovative Academy, No.24/4, Konadasapura, Virgonagar Post, Bidarahalli Hobli, Bangalore-560 049.
03	Name and address of the Building owner	:	Sri Rajappa No.24/4, Konadasapura, Virgonagar Post, Bidarahalli Hobli, Bangalore-560 049.
04	Number of buildings	:	One Building.
05	Number of floors	:	Ground floor.



06	Floor-wise details of occupancy: -	
	Ground floor	: 10 class rooms & 02 wash rooms.
07	Height of the Building.	: 03.00 mtrs.
08	Site area	: 1337.80 sq.mtrs.
09	Built-up area of each floor: -	
	Ground floor	: 691.47 sq.mtrs.
10.	Total built-up area	: 691.47 sq.mtrs.
11	Surrounding properties: -	
	North (Front)	: Private property.
	South(Rear)	: Private property.
	West(Left)	: Private property.
	East(Right)	: Abutting road.
12	Set-back area available around the building: -	
	North (Front)	: 15.00 mtrs.
	South(Rear)	: 07.00 mtrs.
	West(Left)	: 06.00 mtrs.
	East(Right)	: 04.00 mtrs.

B. On inspection of this School premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. (1)	Details (02)	Existing (03)	Recommendations (04)
01.	Accessibility to the premises	The premises is accessible from 10.00 mtrs wide road located on the northern side. The road is hardened to carry the weight of 45.000 kgs.	Complied.
02.	No. of entrances	One entrance cum exit has been provided.	Complied.
03.	Width of Entry/Exit	06.00 mtrs.	Complied.



04.	Fire extinguisher	04no.s ABC type extinguisher of 6 kgs capacity & 01 CO2 type extinguisher of 4.5kgs capacity have been provided.	Complied.
05.	Escape routes	Directions in which the Teachers/Staff/Students have to move in the event of any emergency have been indicated in the corridor of the building as a guide during evacuation. This marking are written in luminous paint.	Complied.
06.	Fire order	A Notice Board indicating with the details of action to be taken by the employees in case of an emergency/fire has been displayed in prominent places.	Complied.
07.	No smoking board.	Displayed.	Complied.
08.	Fire Siren	A fire siren has been installed inside the premises to inform all the inmates in case of a fire emergency and evacuate the area.	Complied.
09.	Nominate one fire Nodal officer.	One non teaching staff has been nominated as fire nodal officer for the school premises.	Complied.
10.	Fire fighting training	Not provided.	40% of the staffs/Teachers shall be got trained in fire prevention, fire fighting & evacuation at R.A.Mundkur fire & emergency service Academy, Bannerghatta road, Bangalore-560 029.
11.	<p>General Fire precaution measures :-</p> <p>A. Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises.</p> <p>B. Accumulation of combustibile waste in and around the premises should be avoided.</p> <p>The exit ways shall be always kept clear without any obstruction.</p>		




- D. Liquefied petroleum gas should be not stored in the building.
- E. The doors shall not be kept locked/latched during working hours and shall be free from obstruction.
- F. During the class hours the class room doors shall not be locked from inside to outside.
- G. As per Hon'ble Supreme Court order all teacher and staff shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety day on April 14th of every year by conducting fire safety drills with co-ordinate with Fire Service Department.
- H. This Fire Safety Recommendation is issued from the fire prevention, fire fighting and evacuation measures. Karnataka State Fire & Emergency Services Department is not responsible for the ownership of the land, its location and other disputes, which may arise in due course.

Under the above circumstance, the Karnataka Fire & Emergency Services Department is issuing Fire Safety Recommendation to "M/s. Rainbow Innovative Academy, No.24/4, Konadasapura, Virgonagar Post, Bidarahalli Hobli, Bangalore-560 049" subject to condition and compliance of the above recommendations as shown in Column-4 of Part-B within 3 months and compliance from the undersigned.

"This Fire Safety Recommendation is valid for Only One Year from the date of issue and it is renewable.

All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.3 of Fire and Life safety will have to be complied with mandatorily.

Yours faithfully,


DISTRICT FIRE OFFICER
MAHADEVAPURA FIRE STATION
BANGALORE



ಚಲನ್ ಚಾಲ್ತಿ ಲವಧಿ Challan Validity	ಜಿಲ್ಲೆ District	ಇಲಾಖೆ Department	ಡಿಡಿ ಕಛೇರಿ DDO Office	
7 Days	BENGALURU URBAN	DEPARTMENT OF KARNATAKA FIRE & EMERGENCY SERVICES	DIVISIONAL FIRE OFFICE, BANGALORE EAST RANGE, KARNATAKA FIRE AND EMERGENCY SERVICES, BANGALORE.	
ವರ್ಗ Category	ದಿನಾಂಕ Date	ಚಲನ್ ಉಲ್ಲೇಖ ಸಂಖ್ಯೆ Challan Reference Number	ಡಿಡಿ ಕೋಡ್ DDO Code	
Government	18/08/2022	CR0822007000438542	140300	
ನಂದಾಯದಾರನ ಹೆಸರು Remitter Name	Rainbow Innovative Academy			
ವಿಳಾಸ Address	Sy.No.24/4, Konadasapura, Virgonagar Post, Bidarahalli Hobli, Bangalore 560 049			
ಉದ್ದೇಶ Purpose	ಲೆಕ್ಕ ಶೀರ್ಷಿಕೆ Head of Account	ಉಪ ಉದ್ದೇಶದ ಹೆಸರು Sub Purpose Name	ಉದ್ದೇಶ ನಿರ್ದಿಷ್ಟ ಐಡಿ Purpose Specific ID	ಮೊತ್ತ Amount
OTHER ITEMS- FIRE DEPARTMENT	0070-60-109-0-02-000	12.FOR ISSUE OF ADVISE ON FIRE PREVENTION AND FIRE FIGHTING FOR NON HIGH RISE BUILDINGS.	NA-	1000
ನಂದಾಯದ ಬ್ಯಾಂಕ್ Remittance Bank	STATE BANK OF INDIA	ಒಟ್ಟು ಮೊತ್ತ Grand Total	1000	
ಪಾವತಿ ಹಂತ Payment Status	Payment Yet To Be Made At Agency Bank	ಒಟ್ಟು ಮೊತ್ತ ಅಕ್ಷರಗಳಲ್ಲಿ Total Amount in Words	One Thousand Only	
ಪಾವತಿ ವಿವರಗಳು\Payment Details				
ಪಾವತಿ ವಿಧ Payment Mode	Cash			


DISTRICT FIRE OFFICER
 MAHADEVAPURA FIRE STATION
 BANGALORE

3-168477191

PF No	6251315	Pravani Devi
Que No		Avalahalli Br.
ವಿಳಾಸ S.B.I.	18 AUG 2022	Branch Code 18236 Blore-19
CASH / CLEARING / TRANSFER		
Maker	Checker - 1	Checker - 2